

SPIRIT LAKE WTP AUTOMATION AND CONTROL UPGRADES, PHASE 2
Spirit Lake, Iowa
2024

CONTRACTOR'S BID DATE: Thursday, September 19, 2024 at 11:00 AM CT

PLACE TO FILE FOR
CONTRACTOR'S BIDS: City of Spirit Lake
City Hall
1803 Hill Avenue
Spirit Lake, IA 51360

ADDENDUM NO. 1
September 17, 2024

TO ALL PLANHOLDERS:



The following changes, clarifications, additions, and/or deletions are hereby made a part of the contract documents for the above-referenced project, as fully and completely as if the same were fully set forth therein. This addendum takes precedence over any items that may conflict.

PLANS

1. Refer to Sheet P203 – WTP MAIN BUILDING GRAVITY SETTLER LOWER LEVEL PLAN:

Replace Keynote #6 with the following:

- “6. CONTRACTOR SHALL CONNECT THE PROPOSED ALUM FEED TUBING FROM THE PROPOSED FEED PUMPS TO THE EXISTING ALUM INJECTION PORTS. CONTRACTOR SHALL ALSO REPLACE THE INJECTION PORT ISOLATION VALVES, CHECK VALVE, AND TUBING WITH 1/2"Ø CPVC BALL VALVE, 1/2"Ø CPVC CHECK VALVE, A SECOND 1/2"Ø CPVC BALL VALVE, AND TUBING PER EACH INJECTION PORT. CONTRACTOR SHALL UTILIZE EXISTING TUBING SUPPORT METHODS.”

	I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly registered Professional Engineer under the laws of the State of South Dakota.	
		Date: 09/17/2024
	MATTHEW JAMES PAJL, P.E.	
	License No. 11935	
	My renewal date is December 31, 2025	
Pages or sheets covered by this seal:		
Entire document		